

Khargone Transmission Limited

I. AC Transmission Line Outage Details for the month of OCT 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV Khandwa-KTL-BR-1 at Khandwa SS	10-04-2024	9:46:00 AM	10-04-2024	5:36:00 PM	07:50	00:00	00:00	00:00	Planned Shutdown for Bushing Tan delta and capacitance testing.	
400kV Khandwa-KTL-BR-1 at Khandwa SS	10-05-2024	9:26:00 AM	10-05-2024	5:28:00 PM	08:02	00:00	00:00	00:00	Planned Shutdown for Bushing Tan delta and capacitance testing.	
765/400kV Khandwa-KTL-ICT-2 at Khandwa SS	10-06-2024	10:18:00 AM	10-06-2024	11:04:00 PM	12:46	00:00	00:00	00:00	Planned Shutdown for Bushing Tan delta and capacitance testing.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	10-07-2024	7:06:00 AM	10-11-2024	10:09:00 PM	00:00	00:00	111:03:00	00:00	Due to Voltage Regulation	
765/400kV Khandwa-KTL-ICT-1 at Khandwa SS	10-07-2024	10:05:00 AM	10-07-2024	7:25:00 PM	09:20	00:00	00:00	00:00	Planned Shutdown for Bushing Tan delta and capacitance testing.	
765KV-Dhule-Khandwa-Sterlite-1	10/14/2024	9:19:00 AM	10/14/2024	7:39:00 PM	10:20	00:00	00:00	00:00	Planned Shutdown for Defect Rectification	
765kV Khandwa-Dhule-LR-1 at Khandwa SS	10/14/2024	9:19:00 AM	10/14/2024	7:39:00 PM	10:20	00:00	00:00	00:00	Planned Shutdown for Defect Rectification	
765kV Khandwa-Dhule-LR-1 at Dhule SS	10/14/2024	9:19:00 AM	10/14/2024	7:39:00 PM	10:20	00:00	00:00	00:00	Planned Shutdown for Defect Rectification	
765KV-Dhule-Khandwa-Sterlite-2	10/15/2024	8:46:00 AM	10/15/2024	6:21:00 PM	09:35	00:00	00:00	00:00	Planned Shutdown for Defect Rectification	
765kV Khandwa-Dhule-LR-2 at Khandwa SS	10/15/2024	8:46:00 AM	10/15/2024	6:21:00 PM	09:35	00:00	00:00	00:00	Planned Shutdown for Defect Rectification	
765kV Khandwa-Dhule-LR-2 at Dhule SS	10/15/2024	8:46:00 AM	10/15/2024	6:21:00 PM	09:35	00:00	00:00	00:00	Planned Shutdown for Defect Rectification	
400kV Khargone(NTPC)-Rajgarh Line	10/21/2024	9:07:00 AM	10/21/2024	8:51:00 PM	00:00	11:44	00:00	00:00	PGCIL Taken the Shutdown For Insulator replacement works.	
400kV Khargone(NTPC)-Rajgarh Line	10/22/2024	9:33:00 AM	10/22/2024	9:19:00 PM	00:00	11:46	00:00	00:00	PGCIL Taken the Shutdown For Insulator replacement works.	
400kV Khargone(NTPC)-Rajgarh Line	10/23/2024	9:06:00 AM	10/23/2024	8:50:00 PM	00:00	11:44	00:00	00:00	PGCIL Taken the Shutdown For Insulator replacement works.	
400kV Khargone(NTPC)-Rajgarh Line	10/27/2024	9:28:00 AM	10/27/2024	8:31:00 PM	00:00	11:03	00:00	00:00	PGCIL Taken the Shutdown For Insulator replacement works.	
400kV Khandwa-Khargone(NTPC) Line					00:00	00:00	00:00	00:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-1					00:00	00:00	00:00	00:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-2					00:00	00:00	00:00	00:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-1					00:00	00:00	00:00	00:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-2					00:00	00:00	00:00	00:00	NO Tripping / Outages in this month	

**Khargone Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of OCT 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of OCT 2024**

**Schedule III**

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil